

## Environmental Protection Licence Monitoring Data



**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** 1/11/2022 - 30/11/2022  
**Website:** [www.westconnex.com.au/NewM5Environment](http://www.westconnex.com.au/NewM5Environment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205

**Monitoring Type:**

Sample Date	Discharge/Monitoring Point	Sampling Method
9 November 2022	Water Treatment Plant ARN-2	Grab Sample

General				Metals (µg/L)										Total Recoverable Hydrocarbons					
pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40	
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result
6.5 - 8.5	7.70	25	23.5	600	20	8.0	2.0	10.3	1.0	10600	1090	150	5.0	<100	<100	<100	<100	<100	<100

**Key**

\*90th percentile concentration limit