

Environment Protection Licence Monitoring Data

Project name:	WestConnex – New M5	
Licensee	CPB Contractors Pty Limited	
Monitoring period	June 2018	
Website:	https://www.westconnex.com.au/NewM5Environment	
Environment Protection licence number/s:	20772	4627
Premise addresses	WestConnex New M5, between Beverly Hills and St Peters, Beverly Hills NSW 2209	New M5 St Peters Interchange, 10-16 Albert Street, St Peters NSW 2044

Monitoring Type: Water Discharge Monitoring

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant SPI-2	1/06/2018	50	*<10	6.5-8.5	7.5	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	1/06/2018	50	*3.8	6.5-8.5	7.76	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	1/06/2018	50	*4.75	6.5-8.5	7.34	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	2/06/2018	50	*<10	6.5-8.5	7.6	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	2/06/2018	50	*4.5	6.5-8.5	7.53	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	2/06/2018	50	*2.76	6.5-8.5	7.16	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	3/06/2018	50	*<10	6.5-8.5	7.3	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	3/06/2018	50	*3.59	6.5-8.5	7.86	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	4/06/2018	50	*<10	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	4/06/2018	50	*4.7	6.5-8.5	7.52	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	4/06/2018	50	*1.83	6.5-8.5	7.6	None visible	None	Each discharge	Compliant

Environment Protection Licence Monitoring Data

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant KGD-1	4/06/2018	50	*2.5	6.5-8.5	7.6	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	5/06/2018	50	*<10	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	5/06/2018	50	*4	6.5-8.5	7.35	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	5/06/2018	50	*3.70	6.5-8.5	6.99	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	5/06/2018	50	*4.2	6.5-8.5	8.27	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	6/06/2018	50	*<10	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	6/06/2018	50	*9.3	6.5-8.5	7.82	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	6/06/2018	50	*1.10	6.5-8.5	6.83	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	7/06/2018	50	*<10	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	7/06/2018	50	*8	6.5-8.5	7.63	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	7/06/2018	50	*2.33	6.5-8.5	7.09	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	8/06/2018	50	*<10	6.5-8.5	6.52	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	8/06/2018	50	*2.73	6.5-8.5	7.22	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	8/06/2018	50	*2.02	6.5-8.5	6.86	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	9/06/2018	50	*25	6.5-8.5	6.67	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	9/06/2018	50	*9	6.5-8.5	7.45	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	9/06/2018	50	*1.98	6.5-8.5	6.83	None visible	None	Each discharge	Compliant

Environment Protection Licence Monitoring Data

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant SPI-2	10/06/2018	50	*<10	6.5-8.5	7.42	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	10/06/2018	50	*3.20	6.5-8.5	7	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	10/06/2018	50	*1.98	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	11/06/2018	50	*<10	6.5-8.5	7.45	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	11/06/2018	50	*1.55	6.5-8.5	6.85	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	12/06/2018	50	*<10	6.5-8.5	7.46	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	12/06/2018	50	*5.30	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	12/06/2018	50	*3.02	6.5-8.5	7.21	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	13/06/2018	50	*<10	6.5-8.5	7.42	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	13/06/2018	50	*3.10	6.5-8.5	7.05	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	13/06/2018	50	*4.85	6.5-8.5	7.58	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	14/06/2018	50	*<10	6.5-8.5	7.05	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	14/06/2018	50	*3.20	6.5-8.5	7.12	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	14/06/2018	50	*5.52	6.5-8.5	7.14	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	15/06/2018	50	*<10	6.5-8.5	7.06	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	15/06/2018	50	*2.70	6.5-8.5	7.21	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	15/06/2018	50	*4.45	6.5-8.5	6.99	None visible	None	Each discharge	Compliant

Environment Protection Licence Monitoring Data

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant KGD-1	15/06/2018	50	*2.4	6.5-8.5	7.5	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	16/06/2018	50	*<10	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	16/06/2018	50	*3.80	6.5-8.5	7.19	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	16/06/2018	50	*7.05	6.5-8.5	7.17	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	17/06/2018	50	*<10	6.5-8.5	7.5	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	17/06/2018	50	*3.1	6.5-8.5	7.2	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	17/06/2018	50	*12.38	6.5-8.5	7.42	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	18/06/2018	50	*<10	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	18/06/2018	50	*7.10	6.5-8.5	7.98	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	18/06/2018	50	*3.00	6.5-8.5	7.87	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	19/06/2018	50	*<10	6.5-8.5	7.5	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	19/06/2018	50	*7.10	6.5-8.5	7.35	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	19/06/2018	50	*3.00	6.5-8.5	7.58	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	19/06/2018	50	*2.7	6.5-8.5	7.68	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	20/06/2018	50	*<10	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	20/06/2018	50	*10.30	6.5-8.5	7.62	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	20/06/2018	50	*2.40	6.5-8.5	7.25	None visible	None	Each discharge	Compliant

Environment Protection Licence Monitoring Data

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant SPI-2	21/06/2018	50	*<10	6.5-8.5	7.3	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	21/06/2018	50	*14.8	6.5-8.5	7.16	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	21/06/2018	50	*3.00	6.5-8.5	7.05	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	22/06/2018	50	*<10	6.5-8.5	7.01	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	22/06/2018	50	*4.4	6.5-8.5	7.39	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	22/06/2018	50	*0.80	6.5-8.5	7.26	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	22/06/2018	50	*1.7	6.5-8.5	7.74	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	23/06/2018	50	*10	6.5-8.5	7.5	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	23/06/2018	50	*7.2	6.5-8.5	7.54	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	23/06/2018	50	*2.77	6.5-8.5	7.14	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	24/06/2018	50	*<10	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	24/06/2018	50	*2.8	6.5-8.5	7.53	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	24/06/2018	50	*4.3	6.5-8.5	6.8	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	25/06/2018	50	*<10	6.5-8.5	7.44	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	25/06/2018	50	*2.43	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	25/06/2018	50	*2.48	6.5-8.5	7.9	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	25/06/2018	50	*7.37	6.5-8.5	7.34	None visible	None	Each discharge	Compliant

Environment Protection Licence Monitoring Data

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant SPI-2	26/06/2018	50	*<10	6.5-8.5	7.01	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	26/06/2018	50	*3.06	6.5-8.5	7.41	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	26/06/2018	50	*2.77	6.5-8.5	8.46	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	26/06/2018	50	*1.0	6.5-8.5	7.58	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	27/06/2018	50	*<10	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	27/06/2018	50	*2.31	6.5-8.5	7.32	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	27/06/2018	50	*11.46	6.5-8.5	7.48	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	27/06/2018	50	*0.9	6.5-8.5	7.72	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	28/06/2018	50	*<10	6.5-8.5	7.3	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	28/06/2018	50	*1.86	6.5-8.5	7.41	None visible	None	Each discharge	Compliant
Water Treatment Plant BED-1	28/06/2018	50	*5.24	6.5-8.5	7.46	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	28/06/2018	50	*2.1	6.5-8.5	8.04	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	29/06/2018	50	*<10	6.5-8.5	7.21	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	29/06/2018	50	*4.3	6.5-8.5	7.31	None visible	None	Each discharge	Compliant
Water Treatment Plant KGD-1	29/06/2018	50	*2.8	6.5-8.5	7.77	None visible	None	Each discharge	Compliant
Water Treatment Plant SPI-2	30/06/2018	50	*<10	6.5-8.5	7.16	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-2	30/06/2018	50	*2.40	6.5-8.5	7.28	None visible	None	Each discharge	Compliant

* A correlation between TSS and Turbidity has been established. Including a safety factor, the turbidity limit is 50NTU.

Environment Protection Licence Monitoring Data

Monitoring Type: **Dust Monitoring (EPL 4627)**

Monitoring Point / EPA Identification point (EPL 4627)	Start Date	Finish Date	Dust Deposition g/m2/month	Comment
SG01	10/04/2018	10/05/2018	14.2	
SG02	10/04/2018	10/05/2018	4.9	
SG03	10/04/2018	10/05/2018	6.3	
SG04	10/04/2018	10/05/2018	8.3	

Environment Protection Licence Monitoring Data

Monitoring Type: Ground Vibration Peak Particle Velocity monitoring

Arncliffe Drivers							
Date	Time	Location		Peak Particle Velocity (mm/s)	Licence Limit (mm/s)	Compliant	Comments
4/06/2018	10:09:01 AM	329380.29	6243216.87	2.732	10	Yes	Drive 4
4/06/2018	10:09:02 AM	329430.17	6243354.27	4.973	10	Yes	Drive 4
22/06/2018	1:50:06 PM	329380.29	6243216.87	3.4	10	Yes	Drive 4
22/06/2018	1:50:02 PM	329430.17	6243354.27	3.398	10	Yes	Drive 4
28/06/2018	5:24:01 PM	329380.29	6243216.87	6.213	10	Yes	Drive 4
28/06/2018	5:24:02 PM	329430.17	6243354.27	3.824	10	Yes	Drive 4

St Peters Drivers							
Date	Time	Location		Peak Particle Velocity (mm/s)	Licence Limit (mm/s)	Compliant	Comments
		Northing	Easting				
5/06/2018	11:16	331207.01,	6245768.32	3.871	10	Yes	Ventilation Drive
5/06/2018	11:16	331268.03,	6245664.58	4.683	10	Yes	Ventilation Drive
7/06/2018	11:10	331207.01,	6245768.32	4.437	10	Yes	Ventilation Drive
7/06/2018	11:10	331268.03,	6245664.58	7.109	10	Yes	Ventilation Drive
7/06/2018	11:10	331152.81,	6245707.32	4.238	10	Yes	Ventilation Drive

Environment Protection Licence Monitoring Data

St Peters Drivers							
Date	Time	Location		Peak Particle Velocity (mm/s)	Licence Limit (mm/s)	Compliant	Comments
		Northing	Easting				
12/06/2018	10:46	331207.01,	6245768.32	3.073	10	Yes	Ventilation Drive
12/06/2018	10:46	331268.03,	6245664.58	5.156	10	Yes	Ventilation Drive
16/06/2018	10:45	331207.01,	6245768.32	2.744	10	Yes	Ventilation Drive
16/06/2018	10:45	331268.03,	6245664.58	4.16	10	Yes	Ventilation Drive
16/06/2018	10:45	331289.25,	6245707.41	2.05	10	Yes	Ventilation Drive
18/06/2018	9:55	331207.01,	6245768.32	3.058	10	Yes	Ventilation Drive
18/06/2018	9:55	331268.03,	6245664.58	7.393	10	Yes	Ventilation Drive
18/06/2018	9:55	331152.81,	6245707.32	2.932	10	Yes	Ventilation Drive
18/06/2018	9:55	331289.25,	6245707.41	2.29	10	Yes	Ventilation Drive
21/06/2018	10:05	331207.01,	6245768.32	2.482	10	Yes	Ventilation Drive
21/06/2018	10:05	331268.03,	6245664.58	6.216	10	Yes	Ventilation Drive
21/06/2018	10:05	331152.81,	6245707.32	2.559	10	Yes	Ventilation Drive
21/06/2018	10:05	331289.25,	6245707.41	2.27	10	Yes	Ventilation Drive
25/06/2018	10:23	331207.01,	6245768.32	2.63	10	Yes	Ventilation Drive
25/06/2018	10:23	331268.03,	6245664.58	7.092	10	Yes	Ventilation Drive
25/06/2018	10:23	331289.25,	6245707.41	2.55	10	Yes	Ventilation Drive
27/06/2018	10:07	331207.01,	6245768.32	2.712	10	Yes	Ventilation Drive

Environment Protection Licence Monitoring Data



St Peters Drivers							
Date	Time	Location		Peak Particle Velocity (mm/s)	Licence Limit (mm/s)	Compliant	Comments
		Northing	Easting				
27/06/2018	10:07	331268.03,	6245664.58	4.8	10	Yes	Ventilation Drive
27/06/2018	10:07	331289.25,	6245707.41	2.06	10	Yes	Ventilation Drive

Environment Protection Licence Monitoring Data



Monitoring Type: Odour Monitoring (EPL 4627)

Date	Monitoring Start Time	Monitoring Finish Time	Surveyor	Wind Direct	Locations															Comments
					OM1			OM2			OM3			OM4			OM5			
					Odour (OU)	H ₂ S (ppm)	NH ₃ (ppm)	Odour (OU)	H ₂ S (ppm)	NH ₃ (ppm)	Odour (OU)	H ₂ S (ppm)	NH ₃ (ppm)	Odour (OU)	H ₂ S (ppm)	NH ₃ (ppm)	Odour (OU)	H ₂ S (ppm)	NH ₃ (ppm)	
1/06/2018	4:05:00 PM	5:10:00 PM	SEMA	SSW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
2/06/2018	1:00:00 PM	2:00:00 PM	CDSJV	SSW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
3/06/2018																				No work involving movement or handling of waste was conducted.
4/06/2018	2:09:00 PM	3:01:00 PM	CDSJV	SSW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
5/06/2018	2:16:00 PM	3:32:00 PM	CDSJV	SSW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
6/06/2018	2:10:00 PM	3:02:00 PM	CDSJV	SE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
7/06/2018	2:02:00 PM	2:50:00 PM	CDSJV	NNE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
8/06/2018	2:50:00 PM	3:22:00 PM	CDSJV	W	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
9/06/2018																				Public Holiday Weekend
10/06/2018																				No work involving movement or handling of waste was conducted.
11/06/2018																				Site closure due to RDO
12/06/2018	2:50:00 PM	3:23:00 PM	CDSJV	NNE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
13/06/2018	3:40:00PM	4:40:00 PM	SEMA	WNW-W	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
14/06/2018	2:06:00 PM	2:59:00 PM	CDSJV	WNW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
15/06/2018	2:08:00 PM	3:03:00 PM	CDSJV	NW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
16/06/2018																				No work involving movement or handling of waste was conducted.
17/06/2018																				No work involving movement or handling of waste was conducted.
18/06/2018	2:00:00 PM	2:39:00 PM	CDSJV	SSW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
19/06/2018	2:34:00 PM	2:55:00 PM	CDSJV	SW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
20/06/2018	3:07:00 PM	4:06:00 PM	CDSJV	S	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
21/06/2018	2:19:00 PM	2:51:00 PM	CDSJV	SSE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
22/06/2018	3:45:00 PM	4:55:00 PM	SEMA	NE-NNE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
23/06/2018	2:17:00 PM	3:08:00 PM	CDSJV	NW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
24/06/2018																				No work involving movement or handling of waste was conducted.
25/06/2018	2:33:00 PM	3:34:00 PM	CDSJV	SSE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
26/06/2018	2:45:00 PM	3:22:00 PM	CDSJV	SSE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
27/06/2018	2:38:00 PM	3:29:00 PM	CDSJV	SE	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
28/06/2018	2:30:00 PM	3:10:00 PM	CDSJV	WNW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
29/06/2018	4:00:00 PM	5:05:00 PM	SEMA	WNW	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.
30/06/2018	2:13:00 PM	4:06:00 PM	CDSJV	NWN	ND	0	0	ND	0	0	ND	0	0	ND	0	0	ND	0	0	No detection at all locations.

¹ND = Non-detect ²All monitoring locations are surveyed/ day