Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M8 Licensee: WCX M5 PT PTY LTD **Monitoring Period:** 1/11/2020 - 30/11/2020

www.westconnex.com.au/NewM5Environment Website:

Environmental Protection Licence: 21351

Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205 Premise Address:

Monitoring Type:

Sample Date	Discharge/Monitoring Point	Sampling Method				
4 November 2020	Water Treatment Plant ARN-2	Grab Sample				

General				Metals (μg/L)									Total Recoverable Hydrocarbons						
I	pH Turbidity (NTU)		Aluminium Cobalt		Copper Manganese		anese	Zinc		C10-C16		C16-C34		C34-C40					
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Results	Limit*	Results
6.5 - 8.5	7.28	25	4.1	600	150	8.0	< 1.0	10.3	< 1.0	10600	984	150	< 5	<100	350	<100	220	<100	<100

Key

*90th Percentile concentration limit



